



Certificate No. 2007-03-444

CERTIFICATE OF TYPE APPROVAL

Applicant : Soo Bog Park

Company : REZONTECH Co., Ltd

Address : 805, Mega Vally, Gwanyang-dong, Dongan-gu,
Anyang-si, Gyeonggi-do, Korea

This is to certify that the following item has been approved in accordance with the provisions of Article 36-① · 37-① of the Fire Facility Establishment Maintenance and Safety Supervision Law and Article 9 · 12-① of the Fire Service Equipment Type Approval Enforcement Regulation.

1. Item : Flame detector
2. Type : DC 24 V, Single type, Normal type, Repeatability type, Explosion resistance type, Outdoor type, Ultraviolet and infrared combined type, Eye Angle 100°, Nominal Detecting Distance 30m
3. Type Approval No. : 감05-29-1
4. Limitation :
5. Reference :

Date : March 6, 2007

President

Korea Fire Equipment Inspection Corporation