Certificate No. 2007-07-1004

CERTIFICATE OF TYPE APPROVAL

Applicant : Soo Bog Park
Company : REZONTECH Co., Ltd
Address : 805, Mega Vally, Gwanyang-dong, Dongan-gu, Anyang-si, Gyeonggi-do, Korea

This is to certify that the following item has been approved in accordance with the provisions of Article 36-① · 37-① of the Fire Facility Establishment Maintenance and Safety Supervision Law and Article 9 · 12-① of the Fire Service Equipment Type Approval Enforcement Regulation.

1. Item : Flame detector
2. Type : DC 24 V, Single type, Normal type, Repeatability type, Explosion type, Outdoor type, Ultraviolet and infrared combined type, Eye Angle 90°, Nominal Detecting Distance 25m
3. Type Approval No. : 감04-14-1
4. Limitation : —/—
5. Reference : —/—

Date : July 11, 2007

President

Korea Fire Equipment Inspection Corporation