

Ex



Certificate of Approval

1. KGS NO. 07-1-532-Q1
2. This certificate is issued for the electrical apparatus :
IR Flame Detector
3. Manufactured and submitted for certification by :
REZONTECH Co.,Ltd.
5 Floor, 1-50, Dongsung-dong, Jongno-gu, Seoul, Korea
4. Rating :
24 V (dc) 50 mA
5. Type (Model) :
RFD-3FT-I
6. Relevant regulations :
"INDUSTRIAL SAFETY & HEALTH LAW ARTICLE 33"
7. This apparatus marking shall include the code :
Ex d IIC T6 IP 66
8. Special condition :
Tamb : -40 °C to +75 °C
9. The term of validity :
18. Sep. 2007 to 17. Sep. 2012

Approved by : 
H D Jung
General Manager

Korea Gas Safety Corporation
332-1, Daeya-Dong, Shihung-shi,
Kyunggi-Do. 429-712. Korea
Tel : 82 31 310 1548 Fax : 82 31 315 4365