



Certificate No. 2007-06-949

CERTIFICATE OF TYPE APPROVAL

Applicant : Soo Bog Park

Company : REZONTECH Co., Ltd

Address : 805, Mega Vally, Gwanyang-dong, Dongan-gu,
Anyang-si, Gyeonggi-do, Korea

This is to certify that the following item has been approved in accordance with the provisions of Article 36-① · 37-① of the Fire Facility Establishment Maintenance and Safety Supervision Law and Article 9 · 12-① of the Fire Service Equipment Type Approval Enforcement Regulation.

1. Item : Flame detector
2. Type : DC 24 V, Single type, Normal type, Repeatability type,
Waterproof type, Explosion resistance type, Indoor type, Infrared type,
Eye Angle 90°, Nominal Detecting Distance 50m
3. Type Approval No. : 감05-30-1
4. Limitation :
5. Reference :

Date : June 28, 2007

President

Korea Fire Equipment Inspection Corporation