

**Ex**



## Certificate of Approval

1. KGS NO. 06-1-362-Q1
2. This certificate is issued for the electrical apparatus :  
IR Flame Detector
3. Manufactured and submitted for certification by :  
REZONTECH Co.,Ltd.  
5 Floor, 1-50, Dongsung-dong, Jongno-gu, Seoul, Korea
4. Rating :  
24 V (dc) 50 mA
5. Type (Model) :  
RFD-3FT
6. Relevant regulations :  
"INDUSTRIAL SAFETY & HEALTH LAW ARTICLE 33"
7. This apparatus marking shall include the code :  
Ex d IIC T6
8. Special condition :  
Warning - "DO NOT OPEN WHEN ENERGIZED"
9. The term of validity :  
06. Nov. 2006 to 05. Nov. 2011

Approved by :   
H D Jung  
General Manager

**Korea Gas Safety Corporation**  
332-1, Daeya-Dong, Shihung-shi,  
Kyunggi-Do. 429-712. Korea  
Tel : 82 31 310 1548 Fax : 82 31 315 4365